

**CERTIFICATE OF ANALYSES**

**GENERAL WATER QUALITY PARAMETERS**

Date received: 2019-06-10

Date completed: 2019-06-25

Project number: 1000

Report number: 83814

Order number:

Client name: Kusini Water

Contact person: Mr. M. Mafuno

Address: 35 Manhattan Street, Paulshof,

e-mail: murendi@kusiniwater.co.za

Telephone: 082 082 0624

Facsimile:

Mobile: 082 082 0624

Analyses in mg/l (Unless specified otherwise)	Method Identification	Risk	SANS 241 : 2015 Limits	Sample Identification	
				Tikello School After	
Sample Number				065548	
Date/Time Sampled				N/A	
pH - Value @ 25 °C	A	WLAB065	Operational	≥5 to ≤ 9.7	7.7
Electrical Conductivity in mS/m @ 25°C	A	WLAB002	Aesthetic	≤170	62.7
Total Dissolved Solids @ 180°C	A	WLAB003	Aesthetic	≤1200	398
Colour in PtCo Units	N	WLAB006	Aesthetic	≤15	2
Turbidity in N.T.U	A	WLAB005	Operational/Aesthetic	≤1 / ≤5	0.1
Total Alkalinity as CaCO <sub>3</sub>	A	WLAB007	---	---	268
Langelier Index at 25°C	A	WLAB053	---	---	0.1
Chloride as Cl	A	WLAB046	Aesthetic	≤300	29
Sulphate as SO <sub>4</sub>	A	WLAB046	Acute health/Aesthetic	≤500 / ≤250	15
Fluoride as F	A	WLAB014	Chronic health	≤1.5	0.2
Nitrate as N	A	WLAB046	Acute health	≤11	6.7
Nitrite as N	A	WLAB046	Acute health	≤0.9	<0.05
Combined Nitrate & Nitrite	A	WLAB046	Acute health	≤1	0.7
Silica as SiO <sub>2</sub>	N	WLAB046	---	---	45
Total Organic Carbon as C	N	WLAB060	Chronic health	≤10	<1.0
Total Coliform Bacteria / (100 ml)	A	WLAB021	Operational	≤10	0
E. coli / (100 ml)	A	WLAB021	Acute health	Not detected	0
Free and Saline Ammonia as N	A	WLAB046	Aesthetic	≤1.5	0.1
Sodium as Na	A	WLAB015	Aesthetic	≤200	79
Potassium as K	A	WLAB015	---	---	3.5
Calcium as Ca	A	WLAB015	---	---	41
Magnesium as Mg	A	WLAB015	---	---	12
Aluminium as Al (µg/l)	A	WLAB015	Operational	≤300	<100
Antimony as Sb (µg/l)	A	WLAB050	Chronic health	≤20	<1
Arsenic as As (µg/l)	A	WLAB050	Chronic health	≤10	1
Barium as Ba (µg/l)	A	WLAB015	Chronic health	≤700	181
Boron as B (µg/l)	A	WLAB015	Chronic health	≤2400	69
Cadmium as Cd (µg/l)	A	WLAB015	Chronic health	≤3	<3
Total Chromium as Cr (µg/l)	A	WLAB015	Chronic health	≤50	<25
Copper as Cu (µg/l)	A	WLAB015	Chronic health	≤2000	<10
Iron as Fe (µg/l)	A	WLAB015	Chronic health/Aesthetic	≤ 2000 / ≤300	<25



J. Ngobeza - Chemical Technical Signatory



N. Ntuli - Microbiological Technical Signatory

**A = Accredited N = Not Accredited S = Subcontracted**

Tests marked "Not SANAS Accredited" in this report are not included in the SANAS Schedule of Accreditation for this Laboratory.

Results marked "Subcontracted Test" in this report are not included in the SANAS Schedule of accreditation for this Laboratory.

Sample condition acceptable unless specified on the report.

The information contained in this report is relevant only to the sample/samples supplied to **WATERLAB (Pty) Ltd**. Details of sampling conducted by Waterlab (PTY) Ltd, according to WLAB/Sampling Plan and Procedures/SOP, are available on request.

**Bacteriological parameters analysed on: 2019-06-10**

**CERTIFICATE OF ANALYSES**

**GENERAL WATER QUALITY PARAMETERS**

Date received: 2019-06-10

Date completed: 2019-06-25

Project number: 1000

Report number: 83814

Order number:

Client name: Kusini Water

Contact person: Mr. M. Mafuno

Address: 35 Manhattan Street, Paulshof,

e-mail: murendi@kusiniwater.co.za

Telephone: 082 082 0624

Facsimile:

Mobile: 082 082 0624

Analyses in mg/l (Unless specified otherwise)	Method Identification	Risk	SANS 241 : 2015 Limits	Sample Identification	
				Tikello School After	
Sample Number				065548	
Date/Time Sampled				N/A	
Lead as Pb (µg/l)	A	WLAB015	Chronic health	≤10	<10
Manganese as Mn (µg/l)	A	WLAB015	Chronic health/Aesthetic	≤ 400 / ≤100	<25
Mercury as Hg (µg/l)	N	WLAB047	Chronic health	≤6	<1
Nickel as Ni (µg/l)	A	WLAB015	Chronic health	≤70	<25
Selenium as Se (µg/l)	A	WLAB050	Chronic health	≤40	1
Uranium as U (µg/l)	A	WLAB050	Chronic health	≤ 30	1
Zinc as Zn	A	WLAB015	Aesthetic	≤5	<0.025
% Balancing	N	---	---	---	97.0



J. Ngobeza - Chemical Technical Signatory



N. Ntuli - Microbiological Technical Signatory

**A = Accredited N = Not Accredited S = Subcontracted**

Tests marked "Not SANAS Accredited" in this report are not included in the SANAS Schedule of Accreditation for this Laboratory.

Results marked "Subcontracted Test" in this report are not included in the SANAS Schedule of accreditation for this Laboratory.

Sample condition acceptable unless specified on the report.

The information contained in this report is relevant only to the sample/samples supplied to **WATERLAB (Pty) Ltd**. Details of sampling conducted by Waterlab (PTY) Ltd, according to WLAB/Sampling Plan and Procedures/SOP, are available on request.

**CERTIFICATE OF ANALYSES**

**GENERAL WATER QUALITY PARAMETERS**

Date received: 2019-06-10  
Project number: 1000

Report number: 83814

Date completed: 2019-06-25  
Order number:

Client name: Kusini Water  
Address: 35 Manhattan Street, Paulshof,  
Telephone: 082 082 0624

Facsimile:

Contact person: Mr. M. Mafuno  
e-mail: murendi@kusiniwater.co.za  
Mobile: 082 082 0624

Information regarding accredited analyses

Analysis	Method Identification	Reporting limit	Average Uncertainty
pH Value	WLAB001	0.6	21%
Electrical Conductivity	WLAB002	0.1 mS/m	7%
Total Alkalinity	WLAB007	5 mg/L	10%
Chemical Oxygen Demand	WLAB018	10 mg/L	16%
Sulphate	WLAB046	2 mg/L	14%
Free & Saline Ammonia	WLAB046	0.1 mg/L	14%
Nitrate	WLAB046	0.1 mg/L	6.2%
Nitrite	WLAB046	0.05 mg/L	10%
Ortho Phosphate	WLAB046	0.1 mg/L	26%
Chloride	WLAB046	2 mg/L	10%
Fluoride	WLAB014	0.2 mg/L	7%
Turbidity	WLAB005	0.1 NTU	8%
Sodium	WLAB015	2 mg/L	13%
Potassium	WLAB015	1.0 mg/L	7.3%
Calcium	WLAB015	2 mg/L	7.8%
Magnesium	WLAB015	2 mg/L	8.0%
Aluminium	WLAB015	0.100 mg/L	7.2%
Cadmium	WLAB015	0.003 mg/L	9.1%
Cobalt	WLAB015	0.025 mg/L	4.6%
Chromium	WLAB015	0.025 mg/L	6.8%
Copper	WLAB015	0.025 mg/L	36%
Iron	WLAB015	0.025 mg/L	3.8%
Manganese	WLAB015	0.025 mg/L	4.4%
Nickel	WLAB015	0.025 mg/L	14%
Lead	WLAB015	0.010 mg/L	7.7%
Zinc	WLAB015	0.025 mg/L	23%
Total Coliform Bacteria	WLAB021	0 CFU/100 mL	6.1%
E. coli	WLAB021	0 CFU/100 mL	23%



J. Ngobeza - Chemical Technical Signatory



N. Ntuli - Microbiological Technical Signatory

**A = Accredited N = Not Accredited S = Subcontracted**

Tests marked "Not SANAS Accredited" in this report are not included in the SANAS Schedule of Accreditation for this Laboratory.

Results marked "Subcontracted Test" in this report are not included in the SANAS Schedule of accreditation for this Laboratory.

Sample condition acceptable unless specified on the report.

The information contained in this report is relevant only to the sample/samples supplied to **WATERLAB (Pty) Ltd**. Details of sampling conducted by Waterlab (PTY) Ltd, according to WLAB/Sampling Plan and Procedures/SOP, are available on request.

**Bacteriological parameters analysed on: 2019-06-10**